



**ANALYTICAL RESULTS**

**Sample:** 7120237-01  
**Name:** PS 1-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:15  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:42	JMW	EPA 200.8

**Sample:** 7120237-02  
**Name:** PS 1-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:16  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:49	JMW	EPA 200.8

**Sample:** 7120237-03  
**Name:** PS 2-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:17  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:50	JMW	EPA 200.8

**Sample:** 7120237-04  
**Name:** PS 2-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:18  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:52	JMW	EPA 200.8

**Sample:** 7120237-05  
**Name:** PS 3-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:23  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:53	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-06  
**Name:** PS 3-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:24  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:54	JMW	EPA 200.8

**Sample:** 7120237-07  
**Name:** PS 4-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:40  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:55	JMW	EPA 200.8

**Sample:** 7120237-08  
**Name:** PS 4-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:42  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:57	JMW	EPA 200.8

**Sample:** 7120237-09  
**Name:** PS 5-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:58  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 07:58	JMW	EPA 200.8

**Sample:** 7120237-10  
**Name:** PS 5-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:00  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:04	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-11  
**Name:** PS 6-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:45  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:06	JMW	EPA 200.8

**Sample:** 7120237-12  
**Name:** PS 6-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 06:46  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:07	JMW	EPA 200.8

**Sample:** 7120237-13  
**Name:** PS 7-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:04  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:08	JMW	EPA 200.8

**Sample:** 7120237-14  
**Name:** PS 7-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:05  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:10	JMW	EPA 200.8

**Sample:** 7120237-15  
**Name:** PS 8-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:07  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:11	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-16  
**Name:** PS 8-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:08  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:12	JMW	EPA 200.8

**Sample:** 7120237-17  
**Name:** PS 9-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:10  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	3.50	ug/L		12/19/17 05:57	12/19/17 08:13	JMW	EPA 200.8

**Sample:** 7120237-18  
**Name:** PS 9-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:11  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	6.69	ug/L		12/19/17 05:57	12/19/17 08:20	JMW	EPA 200.8

**Sample:** 7120237-19  
**Name:** PS 10-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:12  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:21	JMW	EPA 200.8

**Sample:** 7120237-20  
**Name:** PS 10-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:13  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:22	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-21  
**Name:** PS 11-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:31  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:24	JMW	EPA 200.8

**Sample:** 7120237-22  
**Name:** PS 11-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:32  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:25	JMW	EPA 200.8

**Sample:** 7120237-23  
**Name:** PS 12-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:33  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:26	JMW	EPA 200.8

**Sample:** 7120237-24  
**Name:** PS 12-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:34  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:27	JMW	EPA 200.8

**Sample:** 7120237-25  
**Name:** PS 13-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:21  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:29	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-26  
**Name:** PS 13-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 11/30/17 07:22  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:37	JMW	EPA 200.8

**Sample:** 7120237-27  
**Name:** PS 14-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:29  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:38	JMW	EPA 200.8

**Sample:** 7120237-28  
**Name:** PS 14-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:30  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:39	JMW	EPA 200.8

**Sample:** 7120237-29  
**Name:** PS 15-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:32  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	2.64	ug/L		12/19/17 05:57	12/19/17 08:41	JMW	EPA 200.8

**Sample:** 7120237-30  
**Name:** PS 15-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:33  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:42	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-31  
**Name:** PS 16-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:35  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:43	JMW	EPA 200.8

**Sample:** 7120237-32  
**Name:** PS 16-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:36  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:44	JMW	EPA 200.8

**Sample:** 7120237-33  
**Name:** PS 17-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:39  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:46	JMW	EPA 200.8

**Sample:** 7120237-34  
**Name:** PS 17-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 06:40  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:52	JMW	EPA 200.8

**Sample:** 7120237-35  
**Name:** PS 18-1  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 07:25  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
<b>Total Metals - PIA</b>							
Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:53	JMW	EPA 200.8



**ANALYTICAL RESULTS**

**Sample:** 7120237-36  
**Name:** PS 18-2  
**Alias:** MIDWEST CENTRAL PRIMARY

**Sampled:** 12/01/17 07:26  
**Received:** 12/04/17 14:02  
**Matrix:** Drinking Water - Regular Sample

---

Parameter	Result	Unit	Qualifier	Prepared	Analyzed	Analyst	Method
-----------	--------	------	-----------	----------	----------	---------	--------

---

**Total Metals - PIA**

Lead	< 1.00	ug/L		12/19/17 05:57	12/19/17 08:55	JMW	EPA 200.8
------	--------	------	--	----------------	----------------	-----	-----------